

Attestation

Based on the Test Report No. 40665-001 (II) dated 2013-09-12

Product:

Milacor Whiteboard Finish Aqua

Milacor Techn. Handel, Am Wiesengrund 5, D-33449 Langenberg

Evaluation of the emissions test results according to AgBB (Committee for Health-related Evaluation of Building Products) and DIBt (German Institute of Structural Engineering) guidelines

Carcinogenic substances (Cat 1 und 2 acc.to 67/548/EWG) have not been detected after 3 days (<1µg/m³).

The sum of VOC (defined as TVOC) after 3 days was below 10 mg/m³.

The sum of VOC (defined as TVOC) after 28 days was below 1.0 mg/m³.

The sum of SVOC after 28 days was below the limit of 0.1 mg/m³.

The R-Value after 28 days calculated with single VOC concentrations above 5 µg/m³ was below the limit of 1 (without dimension)

The sum of VOC without LCI after 28 days was below the limit of 0.1 mg/m³.

Sampling, testing and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9 and ISO 16000-11

The tested product complies with the requirements of DIBt (10/2010) in combination with the NIK values from AgBB (06/2012) for use in indoor environment.

Cologne, 2013-09-12

eco-INSTITUT GmbH



Daniel Tigges, Dipl.-Holzwirt
(Project Manager)

Nach DIN EN ISO/IEC 17025 akkreditiertes Prüflabor

